



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Murshidabad**  
**West Bengal Fire & Emergency Services**  
**C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101**

Memo no.:IND/WB/FES/20192020/62201

Date: 02-03-2023

**From:**

**Divisional Fire Officer, Murshidabad**  
**West Bengal Fire & Emergency Services**

**To: Elias Choudhury Academy**

**Run by Chowdhury Minority Trust, Over Plot No. 2430, Kh. No. (New) 5462, J.L.No.708, Mouza-Barala, at Village and P.o -Barala, Ps-Raghunathganj, Dist-Murshidabad, W.B, Pin-742235**

**Sub: Renewal of Fire Safety Certificate for a G+III storied Educational Building named as "Elias Chowdhury Academy" Run by Chowdhury Minority Trust at Mouza-Barala; Kh.No.-(old & New)-511 & 5462, Plot No.-2430, J.L.No.-108, Vill + P.O.-Barala, P.S.-Raghunathganj, Dist.-Murshidabad, Pin.-742235.**

This is in reference to your application no. 0125191220900058 dated 01-12-2022 regarding the Renewal of Fire Safety Certificate for a G+III storied Educational Building named as "Elias Chowdhury Academy" Run by Chowdhury Minority Trust at Mouza-Barala; Kh.No.-(old & New)-511 & 5462, Plot No.-2430, J.L.No.-108, Vill + P.O.-Barala, P.S.-Raghunathganj, Dist.-Murshidabad, Pin.-742235.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.

- 4.Existing Electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
- 5.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the building.
- 6.The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
- 7.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 8.A trained Fireman shall be maintained round the clock for safety of the building.
- 9.First-Aid Fire Fighting system shall be provided as per I.S. Specification.
- 10.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- 11.Another stand by pump shall have to be provided within three month.
- 12.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 13.Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above-mentioned system.
- 14.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 15.This Renewal Fire Safety Certificate is valid for three years and have to be renewed within stipulated period from the date of issue of this letter.
- 16.Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this RFSC will be treated as cancelled.

Signature valid

Digitally Signed.  
Name: SUBRATA GUHA  
Date: 02-Mar-2024 16:48  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Murshidabad  
West Bengal Fire & Emergency Services



4. Existing Electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
7. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. A trained Fireman shall be maintained round the clock for safety of the building.
9. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
10. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
11. Another stand by pump shall have to be provided within three month.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
13. Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above-mentioned system.
14. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
15. This Renewal Fire Safety Certificate is valid for three years and have to be renewed within stipulated period from the date of issue of this letter.
16. Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this RFSC will be treated as cancelled.

Signature valid

Digitally Signed.  
Name: SUBRATA GUHA  
Date: 02-Mar-2024 10:48  
Reason: Approved  
Location: West Bengal

Divisional Fire Officer, Murshidabad  
West Bengal Fire & Emergency Services